

There is small wind turbine production in Córdoba and Buenos Aires (INVAP), which devices would not resist Patagonian gusts of wind.

The National Grid in the Middle and South Patagonia has about 132kV lines which become saturated during the peak hour. This regional grid needs to be interconnected with the National Grid of 500kV which will permit to export to the rest of the country from 1000MW (2006: one simple line) to 3000 MW (In the future: two compensated line). The first span of 500kV from Choele Choel to Puerto Madryn was finished during 2005, but primarily this line will be used to transport energy from Combined Cycle Power Station using residual natural gas

[5]. It is proposed to combine the production of electrical energy with a Wind Farm of 200MW [6].

There are some implementations of Hydrogen obtained by electrolysis of water with energy from wind turbines in Pico Truncado but it is a subsidized investment by the National Government. The H₂ –production is about 1m³ per day only for R&D.

The Installed power of Wind Turbines in operation in Argentina is represented in Table 1. The company locations are represented by numbers in Figure 1.

TABLE 1: Wind Turbine Installations in operation in Argentina.

Province	Company (see Fig. 1)	Wind Speed	Date	Purchaser	Total Power KW
Buenos Aires	1.CRETAL – Tandil	7,2 m/s	26/05/95	MICON 2x400KW	800
	2.CEPA – Pehuen Có	7,3 m/s	17/02/95	MICON 1x400KW	400
	3.CEPA – Bajo Hondo	7,8 m/s	10/12/98	BONUS 3x600KW	1.800
	4.CED – Darregueira	7,3 m/s	12/10/97	MICON 1x750KW	750
	5.CEMB - M.Buratovich	7,4 m/s	22/10/97	BONUS 2x600KW	1.200
	6.CEC - Claromecó	7,3 m/s	26/12/98	MICON 1x750KW	750
				TOTAL	5.700
Chubut	7.PECORSA	11,2 m/s	19/01/94	MICON 2x250KW	500
	8.C.Rivadavia	11,2 m/s	12/09/97	MICON 8x750KW	6.000
	8.CEECR- C.Rivadavia		10-12/01	GAMESA 16x660 KW	10.560
			18/3/96	MICON 1x400KW	400
				TOTAL	17.460
La Pampa	9.COAGUA- Rada Tili	10,8m/s			
	10.CSPGA – Gral. Acha	7,21m/s	12/02	NEG-MICON 1x900KW	1.800
			02/04	NEG-MICON 1x900KW	
Neuquén	11.COPELCO – Cutral Có	7,2 m/s	20/10/94	MICON 1x400KW	400
Santa Cruz	12. MPT – Pico Truncado	9m/s	02/01-	ENERCON	2.400
			02/05	4x600KW	
TOTAL WIND POWER IN OPERATION, ARGENTINA					27.760

Enercon installed a plant for assembling and manufacturing in Brazil for their biggest wind turbines. During July 2006, the first Argentinean private prototype of 1MW turbine fell down in Comodoro Rivadavia. It belongs to Pescarmona Company.

Dr. Kirchner, Argentinean president, created the new State Energy Enterprise (ENARSA) which will try to develop new non renewable fuel prospecting and renewable energy investments.

The installation of wind turbines is limited to 1,5-2 MW in Argentina, because there are no cranes for more than 50m high nacelles. Investments for more than 2MW per machine, justify to import the respectively crane for 70m height.

On the other hand there are some Universities in Argentina that offer research, training and careers related to Renewable Energy. The University of Salta offers an MSc Course mainly oriented to Solar Energy.

National University of Comahue (UNCo) included Renewable Energy in Secondary or High School Teacher Training.

There is a Research Group in Energy and Sustainability (UNCo) which developed a Vertical Axis Wind Turbine particularly for wind characteristics near the mountain range. National University of Austral Patagonia (UNPa) offers a Mechanical Engineer career with specialization in Renewable Energy [7]. National Technological University (UTN) by means of Academic Unit of Confluence, Plaza Huincul, Neuquén, offers a Technical Degree of two years preparing technician for operation and installation of Renewable Energy investments [8].

Specialized Workers salary is from US\$ 500 to US\$ 700 and for ordinary workers US\$ 300 to US\$ 500.

2. Prospects into the future:


The first aspect is to analyze the **Meteorological Wind Potential**. Taking into account, Dr. Barros' studies, the wind potential at 10m height is about 200.000MW.

If we analyze at different height than 10m this potential results in the values shown in Table 2.

TABLE 2: Wind Potential at different Heights using the log law of wind profile applied to power production

Magnitude	Power Pzr	Zr	Zo	Z	ln1 : ln (Z/Zo)	ln2: ln(Zr/Zo)	Pzr.(ln1/ln2) ³
Value	200000	10	0,1	34	5,83	4,61	405567
				50	6,21	4,61	491512
				60	6,40	4,61	536053
				78	6,66	4,61	604752
				100	6,91	4,61	675000
Unit	MW	m	m	m			MW

Z: heights obtained from the performance of VESTAS and ENERCON turbines from 400kW to 3MW.



Map References:

- 500kV High Voltage Lines in present operation
- - - 500kV High Voltage Lines in operation in 2007
- 500kV High Voltage Lines in future operation

Fig. 2: High Voltage System in Argentina

The second aspect is the **Technological Wind Potential**. Some considerations are necessary to estimate this aspect:

1. There is a constraint about height of cranes used to fit the nacelles. The availability of cranes is up to 50 m height.
2. In this way the power is limited between 1 and 2MW in the best condition of wind characteristic.
3. It is necessary a High Voltage Transmission System of 500kV to export energy to others areas or countries.

Taking into account the upper considerations on Atlantic area of Patagonia from Golfo San Matías to Río Gallegos, a wind power generation of about 20.000MW using machines around 1,5 could be obtained in Patagonia in the best case at present [8][9].

The available Total Power from electrical generation plants connected to the Whole Sale Energy Market in Argentina is about 24000MW. As electrical procedures establish, 20% of installed available power stations can be supplied by wind energy, so the possible local wind energy market today is up to 4800MW.

The last limitation in Argentina for wind energy is the distribution transmission line system of 132kV . The present local High Voltage System has 132kV lines which are saturated. The new 500kV line from Choele Choel to Puerto Madryn was finished during 2005 [10]. It can transmit 1000MW. During 2006, a local company offered to install a power plant from 350 to 500MW with natural gas as fuel and a wind farm up to 200MW near Puerto Madryn. The second track of 500kV line will be installed from Puerto Madryn to Pico Truncado. This city has a County's Investment of 2,4MW of wind energy (see Table 1) and has an experimental plant for producing Hydrogen. This line will be finished during 2007, (expected for August). The third track of 500kV line from Pico Truncado to Río Gallegos is projected to be in service in the next future (2010). This Patagonian 500kV System was primarily designed to export non renewable energy, although there is capability to export 1000 MW from renewable or non renewable energy.

In the case to intend installations of Manufacture Wind Turbine Company, there are some different strategic sites. Table 3 presents a comparison of North and middle location in Patagonia.

TABLE 3: Comparison of locations to install a manufacturing Wind Turbine Plants

Place	Advantages	Disadvantages	Other Considerations
Neuquén-Cipolletti	It is in the midway between Atlantic and Pacific Oceans with access to respective harbors for export. Routes and train is available to access the harbors.	It is not near the best places of wind in Patagonia.	It is in the Comahue region. North Patagonia. Harbor in Argentina: San Antonio Este. Harbor in Chile: Saavedra through Temuco.
Puerto Madryn - Comodoro Rivadavia	It is near the best places of wind in Patagonia. They are near the harbor for Atlantic Ocean	There is no a good harbor in Chile for exporting wind turbines through Pacific Ocean at this latitude.	It is in the middle of Patagonia region on the Atlantic area.

The third aspect is to consider the **Business Potential** to develop wind energy investments.

The worker salaries are around Asian figures, and therefore the worker market is competitive. Then the installation costs can be cheaper than in Europe or Asia with good technical level because of the energy installations during the 1990s.

The Wholesale Electrical Energy Market price in Argentina is the cheapest in Latin America, from 2001. In 2000 the average energy price was about 0,004 US\$/kW and now is about 0,001US\$/kW and fixed by de Secretary of Energy Office[10]. During 2006, the Government establish free prices for new private energy contracts and deals between Energy Generation Companies and Demand Companies. In this way there was a partial free-trade in Whole Sale Energy Market.

It is possible to analyze different situations for investments taking into account different energy prices with the following consideration frame:

- Energy prices in the Whole Sale Energy Market: present value (1,3US\$/MW) and possible ones in the future (2,3 to 4 US\$/MW).
- Period of useful operation: 25 years. It is the ordinary period for generation engines
- Investment: Wind Farm of 100MW at 1000US\$/MW: Total of US\$ 100.000.000.
- Costs of Maintenance/Operation US\$100.000 per year – It is supposed three workers for maintenance and two form operations.

- Cost of Land: it is negligible because they are fiscal or public lands.
- Coefficient Plant: Patagonia is divided in two regions: CP=0,3 in North Patagonia and CP=0,4 in Atlantic and Middle land zone of Chubut and Santa Cruz.

Taking into account the upper considerations on Net Present Value (NPV) calculations, their results are in Table 4.

TABLE 4: Economical Approach for Wind Energy Investment

Comparison	Plant Coeff. : 0,30	Plant Coeff. : 0,40
Energy Price	Net Present Value	Net Present Value
1,3	Negative	Negative
2,3	Negative	Positive
4	Positive	Positive
(US\$/MW)		

NPV was chosen because it is the investing indicator more simple and effective than others. Also this economical comparison tries to be only and approach to good conditions for wind energy business.

3. Conclusion and Considerations:

It is possible to produce wind energy in Argentina but the following considerations in Table 4 should be put in practice:

TABLE 4: Conclusions and Considerations

Consideration	Reference
With the actual technology the Meteorological Wind Potential is between 500.000 to 600.000 MW, with the limitation of cranes availability in Argentina.	Table 2
The best area to produce wind energy in Argentina is in Chubut and Santa Cruz provinces (Puerto Madryn – Comodoro Rivadavia – Pico Truncado – Gobernador Gregores).	[1] Barros, 1985
There are High Voltage Transmission Lines (500kV) to Puerto Madryn, in the next future (august 2007) there will be to Pico Truncado. It is possible to transmit up to 500MW today of Wind power in Argentina from Patagonia.	[8] Labriola, 2006

The target in the next future (2020) is to obtain 8% from renewable Energy in the Whole sale Energy Market (Today 8% represents nearby 1600MW).Also with the limit of 20%, it could be possible to generate up to 4800MW but more 500kV HVTL are necessary to export the energy to other areas or countries.	[4] National Law, 2006
The present fixed energy price in the Whole Sale Market by Argentinean Secretary of Energy is not enough for wind energy investment. It is necessary to rise the energy price to between 2 to 3 U\$\$/MW for CP=0,4 or nearby 4 U\$\$/MW for CP=0,3, by means of new energy contracts or/and National plus Provincial subsidies. These figures permits to begin thinking about wind energy generation business could be profitable. It is necessary to convert the subsidies from \$ to dollar with the same figure.	Table 4 [8] Labriola, 2006. [4] National Law, 2006
500kV Transmission Lines on Neuquén are very close to Transmission Line System of South Chile. It is possible to interconnect them for exporting energy at international prices instead of natural gas. But it is not possible in the present condition of energy deficit in Argentina.	[8] Labriola, 2006.
If it is not possible to increase the present price or subsidies, it is necessary 50% of capital participation by the Argentinean Government.	[8] Labriola, 2006
Local careers and technician training are already available. These qualified workers can be included into Wind Energy production in construction, installation, operation and supervision areas. Salaries are one third to one half of international ones for qualified workers.	[7] Labriola, 2005 [8]Labriola, 2006

The technical scene and an approach to economical scene is set. As we all know any engineering system is embedded in political, juridical, economical and social systems on which it depends. This is to say that technical decisions and performance is conditioned by many and different factors beyond engineering issues, mainly in developing countries.

Finally we must view the development of energy systems in general and wind energy in particular, as holistic and multidisciplinary processes which lead to decision making [11]

Acknowledgements:

- To UNCo which permits my specialization.
- To UTN which permits to apply on working areas.
- To National University of La Plata which permits to continue my PhD studies.

References:

- [1] Barros, V.: Wind Map of Argentina with 20 years of Data, 1985.
- [2] Lässig, E. -Palese, C.: Study of wind behaviour in Comahue Region, International Congress of Electrical Distribution, Mar del Plata, Buenos Aires Province, 1990.
- [3] COPELCO: First International Course o Wind Energy Maintenance in Latin America, Cutral C6, Neuquén, organized by COPELCO Cooperative, MICON and CREE, March 1995.
- [4] National Law of Renewable Energy, 2006: It include geothermal and Biomass in the former RE Law (1998) which proposed Wind and Solar energy subsidies with \$1/MW of RE generation.
- [5] N.E.E.P: National Electrical Energy Plan, 1990-2000.
- [6] Trelew, 2006: Provincial announcement that there will be a local Investment of nearby 500-700MW of Renewable and Non Renewable Energy Power plants at 50Km form Trelew, Chubut province.
- [7] Labriola, C., 2005: Technicature of Renewable Energy and Environment, National Technological University, Argentina 2003-2005.
- [8] Labriola, C., 2006: Presentation during the annual meeting of "European Renewable Energy RTD and International Cooperation", Florence, Italy august 2006.
- [9] Labriola, C., 2000: 5th. Chapter of Thesis of MSc. Course in The University of Reading, United Kingdom, September, 2000.
- [10] CAMMESA, 2006: Whole Market Electrical Company of Energy Transactions, Reports from 1999-2006.
- [11] Blockley, D. -Godfrey, P.,: "Doing it differently", Thomas Telford Limited, Bristol, UK, 2000.