



## Comparison of R744 and R134a heat transfer coefficients during flow boiling in a horizontal circular smooth tube

R. Mastrullo<sup>1</sup>, A.W. Mauro<sup>1</sup>, A. Rosato<sup>1</sup>, G.P. Vanoli<sup>2</sup>

<sup>1</sup> D.E.TE.C., Facoltà di Ingegneria, Università degli Studi di Napoli Federico II, p.le Tecchio 80, 80125 Napoli, Italy,  
Fax number: +39 (0)81 2390364, E-mail: [antonio.rosato@unina.it](mailto:antonio.rosato@unina.it)

<sup>2</sup> Dipartimento di Ingegneria, Università degli Studi del Sannio, corso Garibaldi 107,  
Palazzo dell'Aquila Bosco Lucarelli, 82100 Benevento, Italy

### Abstract

In last and recent years new regulations and protocols concerning the environmental impact of refrigerants have led to the research of new environmental friendly refrigerants. In this contest the carbon dioxide (R744) is considered as one of the most promising substitute of the actually most widely used refrigerant in commercial refrigeration: R134a. However, some technical and thermodynamic problems avoid a widespread use of R744 in refrigeration applications. Referring to the performances of R744 in refrigerating applications, they are influenced by the design of components. In order to study the heat transfer characteristics at refrigerant side during flow boiling of R744 and to compare its behaviour to that of R134a, the authors carried out experiments in several working conditions usually encountered in commercial refrigeration. In this work are presented the experimental results of heat transfer coefficients for R744 and a comparison with those for R134a in the whole range of vapour qualities for a heat flux equal to  $10 \text{ kW/m}^2$  varying the mass flux between 200 and  $350 \text{ kg/m}^2\text{s}$  and the saturation temperature between  $-8.0 \text{ }^\circ\text{C}$  and  $+5.0 \text{ }^\circ\text{C}$ .

### Key words

R134a, R744, heat transfer coefficient, flow-boiling, evaporator, refrigeration.

### References

- [1] EC Regulation 2037/2000, 2000.
- [2] UNEP, Report of the refrigeration, air - conditioning and heat pumps technical options committee, 2006.
- [3] Cavallini A., Zilio C., Carbon dioxide as a natural refrigerant, 5th International Congress on Sustainable Energy Technologies, Vicenza, Italy, 2006.
- [4] De' Rossi F., Mauro A. W., Rosato A., Confronto delle perdite di carico dell'R744 e dell'R134a durante l'evaporazione in convezione forzata, Proceedings of 63° Congresso Nazionale ATI, Palermo, 2008.
- [5] Moffat R. J., Describing uncertainties in experimental results, Experimental Thermal Fluid Sciences 1 (1988) 3-17.
- [6] Lemmon E. W., Mc Linden M.O., M.L. Huber, NIST Standard Reference Database 23, Version 7.0, Physical and Chemical Properties.
- [7] Cheng L., Ribatski G., Moreno Quibén J., Thome J. R., New prediction methods for CO<sub>2</sub> evaporation inside tubes: Part I - A two-phase flow pattern map and a flow pattern based phenomenological model for two-phase flow frictional pressure drops, International Journal of Heat and Mass Transfer 51 (2008) 111-124.